

C 80

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 312

Dated: 29/04/2022

To,

The Manager,
M/S Hotel R. S. International,
A-24/7880, Arakashan Road,
Pahar Ganj, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Hotel R. S. International located A-24/7880, Arakashan Road, Pahar Ganj, New Delhi. ID No. 2022040205228 dated 02.04.22.

Sir,

This has reference to on line ID No. 2022040205228 dated 02.04.22 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 22/04/2022 in the presence of **Manager** and following shortcomings were observed: -

1. Smoke management system not provided as per gazette notification dated 27.05.2019.
2. PA system found nonfunctional.
3. Pump not in auto mode provision start.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,


26/4/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to

1. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony, New Delhi.