

C.54

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No. F6/DFS/MS/GH/NDZ/2022/ 310

Dated: 29/04/2022

To

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

**Sub:** Regarding renewal of Fire Safety Certificate in respect of **M/s Rabbi Guest House** located at **1141, Haveli Sadar Sadoor, Matia Mahal, Jama Masjid, Delhi.**

Sir,

With reference to online application I.D. no. 2022040605818 dated 06.04.2022 on the subject cited above, it is informed that the guest house was inspected by Assistant Divisional Officer (SPM) from this department on 18.04.2022 in the presence Mr. Iqbal (Manager) and it was observed that building is comprised of Ground + Mezzanine + 04 upper floors. During inspection, following shortcomings were observed:

1. Fire extinguisher found non functional.
2. First Aid Hose reel found non functional.
3. Public Address System not provided.
4. Fire pump found not functional and not in auto start mode.
5. Exit Signage not adequately provided.
6. Third and fourth floor use not permitted as per gazette notification dated 27.05.2019 and shall not be used for any purpose.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
29/4/22

**(Dr. S.K. Tomar)**

Dy. Chief Fire Officer

Tel: 011-23412025

**Copy to:-**

The Licensee,

Rabbi Guest House at 1141, Haveli Sadar Sadoor, Matia Mahal, Jama Masjid, Delhi.

82  
29/4