

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI – 110001

No.F6/DFS/MS/School/SZ/2022/ 198

Dated: 29/04/2022

To

The Principal,
Shiv Shakti Modern Public School
L-1st, B-106, Sangam Vihar, New Delhi-80.

Sub:- Regarding renewal of Fire Safety Certificate in respect of **Shiv Shakti Modern Public School located at L-1st, B-106, Sangam Vihar, New Delhi-80.**

Sir,

With reference to letter no. nil dated 21.03.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 06.04.2022 in the presence of Mr. Satish Kumar, Owner and it was observed that the building which was earlier comprised of basement, ground + 02 upper floor is now comprised of basement + ground + 03 upper floors and hence is a case of addition/alteration. The fire and life safety requirements applicable are as prescribed in Unified Building Byelaws 2016 and National Building Code 2016 as per which following shortcomings were observed:-

1. Alternate staircase having width not less than 1.50 mtrs must be provided from 2nd floor to 3rd floor & basement.
2. First aid hose reels found non function.
3. Sprinkler system not provided in basement.
4. Fire pump of 225 LPM discharge provided against the requirement of fire pump of 900 LPM discharge.
5. Exit signages not provided.
6. Polyvinyl shed shall be replaced by non combustible material shed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Singh)
Director

Delhi Fire Service

Copy to:-

The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.