

C-100

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/2022/SZ/HTL/14

Dated: 22/4/2022

To

The Joint Commissioner of Police,
Lic Branch 1st Floor, Police Station,
Defence Colony New Delhi 110049

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Svelte Hotel & Personal Suits, select City Walk, A-3 District Center, Saket, New Delhi-110017

Sir,

This is in reference to with MHA Portal ID 2022040104945 dated 04/04/2022 on the subject cited above. The premise was inspected by the concern nominated authority of this department in presence of Mr. Kishan Kumar on 11/04/2022 & observed that the building is comprised of 3 tier B+G+ 07 upper floors but Hotel is running at 3rd floor to 7th floor only. During the course of inspection, the following shortcoming observed were noticed:-

1. The Pressurization lifts lobbies & Staircases not functional.
2. Some portion of First Basement is use being as a meeting hall.
3. Exit Signage found removed at some places in floor.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR/DFS

Copy to: -

1. M/s Svelte Hotel & Personal Suits, select City Walk, A-3 District Center, Saket, New Delhi-110017