

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/NDZ/2022/ *caus/970*

Dated: *02*.05.2022

To

Sh. Punit Gupta,
President,
Saraswati Co-operative Group Housing Society Ltd.,
97, I.P. Extension, Patparganj, Delhi – 92.

Subject:- Regarding issuance of Fire Safety Certificate in r/o Saraswati Co-operative Group Housing Society Ltd., 97, I.P. Extension, Patparganj, Delhi – 92.


Sir,

This has reference to your letter no. Saraswati/S-01-C/20-21/71 dated 10/11/2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 20/04/2022 in the presence of Mr. Ravinder Kumar (Manager) and the following shortcomings were observed :-

1. 06 mtr. access encroached due to parking.
2. Hose reel not functional.
3. Fire pump not functional.
4. MCP not functional.
5. Exit signage & lift signage not provided.
6. status of addition or alternation.

In view of above, Fire Safety Certificate cannot be considered at this stage. Further, you are advised to apply for issuance of FSC after rectification above mentioned short comings under intimation to this department for further action in this matter.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service