

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F.6/DFS/MS/NDZ/2022/ 948

Dated: -29 .04.2022

To ✓

The Chief Engineer,
Engineering Department,
Jeevan Bharati Building,
124, Connaught Place, New Delhi – 110001.

Sub:- Regarding renewal of FSC in r/o Jeevan Bharati Building, 124, Connaught Place, New Delhi.

Sir,

This has reference to your letter no. NZO/Engg./Elect/Fire dated 21/03/2022 on the subject cited above, it is to inform that the site was inspected by the officers concerned of this department on 19/04/2022 in the presence of Sh. S.M. Surana Estate Officer Sh. R.N. Raina EE (E) on 19.04.2022 and following shortcomings were observed

1. Alternative exit found blocked by storage of goods at 7, 8th floor of tower-2 and 9th floor of Tower -1.
2. Fire Check doors are not provided at lift lobby at some floors of both towers for compartmentation of floors.
3. Detectors are not provided in some offices.
4. First aid hose reel not covering entire floors area required to be extended in left out areas at floors level.
5. MOEFA found nonfunctional at floors.
6. Exit signages found inadequate.

In view of above, the request for renewal of shortcomings is rejected. The occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

The Chief Architect, New Delhi Municipal Council, Palika Kendra, New Delhi.