

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F-6/DFS/MS/2022/WZ/ 955

Dated: 29/4/22

To,

Sh. Ashish Mangla,
Mangla Shree Properties(P) Ltd.
Plot No. F.C-1, B-Block, DSIIDC Narela, Delhi-40.

**Sub:- Renewal of Fire Safety Certificate in respect of Mangla Shree Properties(P) Ltd.
located at Plot No. F.C-1, B-Block, DSIIDC Narela, Delhi-40.**


Sir,

Please refer to your application received via outdoor diary no. 7284 dated 14.03.2022 on the subject cited above. In this connection it is to inform you that the premises was visited by officer concerned of this department on 13.04.2022 in presence of Sh. Ashish Mangla to verify the fire safety arrangements installed. Your request for renewal of Fire Safety Certificate is rejected under sub rule (3) of Rule 37 of Delhi Fire Service Rules 2010, due to following shortcomings.

1. First-Aid hose reel found not functional.
2. Smoke/Heat detectors found not functional.
3. MOEFA found not functional.
4. Public Address System found not functional.
5. Exit signage's found removed.

You are requested to apply again after compliance of the above mentioned shortcomings for further consideration in this matter.

Yours faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
WEST ZONE

Copy to-

1. The Executive Engineer (B) M.C.D., Narela Zone, Narela, Delhi-110040.