

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No. F6/DFS/MS/Hospital/2022/ 394

Dated:- 18 /02/2022

To

The Medical Superintendent,
Ram Lal Kundan Lal Orthopaedic Hospital,
Plot no. 8, Pandav Nagar, Patpar Ganj Road, Delhi – 110092.

Sub:- Regarding renewal of Fire Safety Certificate of Ram Lal Kundan Lal Orthopaedic Hospital, Plot no. 8, Pandav Nagar, Patpar Ganj Road, Delhi – 110092.


Sir,

This has reference to your letter no. nil dated 01/01/2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 27/01/2022 in the presence of Mr. Pankaj Kapoor (Admin officer) and the following shortcomings were observed:-

1. Smoke management system not integrated.
2. Detectors provided but not functional in basement.
3. Fire Check doors found removed at some locations.
4. LPG kitchen running at terrace must be stopped immediately as it has narrow small door & sleeping accommodation in narrow gaps.
5. Additional/Alteration work in progress at one floor hence could not be inspected.
6. Pump not on auto mode.
7. Reception in corridor corner to be shifted as this is reducing the width of corridor.

Hence Fire Safety Certificate can not be considered at this stage.

Yours faithfully


(Anil Garg)
Director
Delhi Fire Service
ok
MD