

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F6/DFS/MS/GH/2022/NDZI/325

Dated: 04/05/2022

To,
The Joint Commissioner (Lic.)
1st floor Police Station Defence Colony,
New Delhi

Sub:- Regarding Issuance of Fire Safety Certificate in r/o Guest House located at Plot No. 9BT111 & 9BT112, Subhash Gali Vishwas Nagar, Gali No. 9, Shahdara, Delhi- 110032.

Sir,

With reference to your online application No. 2022022202485 dated 23/02/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department inspected the premises from fire safety point of view in presence of Mr. Sanjay on dated 21/03/2022 & 04/04/2022. The building comprised of basement, still & ground plus three upper floors. Guest house is proposed on upper ground floor, first floor, second floor, third floor. Following shortcomings were observed during the time of inspection.

1. Fire check doors not provided in the building.
2. Carbon monoxide detectors not provided in the building.
3. Down comer, Hose reel and terrace pump were provided but found non functional.
4. Fire pump is not on auto mode..
5. Attached plans is not matching with actual site.

In view of above, the application for issuance Fire Safety Certificate is rejected. The occupancy of building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(Atul Garg)
Director

Delhi Fire Service

o/c
e.

Copy to:-

Mrs. Madhu Surana M/s Guest House, Plot No 9BT111 & 9BT112, Subhash Gali, Vishwas Nagar, Gali No. 9, Shahdara, Delhi- 110032.