

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/School/2022/ 205

Dated: 04/05/2022

To

The Principal,
North M. C. Pry. Girls School,
E-1, Sultanpuri, Rohini Zone
New Delhi-110086.

Subject: Issuance of Fire Safety Certificate in r/o North M. C. Pry. Girls School, E-1, Sultanpuri, Rohini Zone, New Delhi-110086.

Sir,

This is in reference to your letter No. nil dated 03.03.2022 received through outdoor diary no. 7054 dated 04.03.2022 on the subject cited above. In this connection submitted the building was visited by officer on dated 06.04.2022 however, it has been observed that the shortcoming already issued by this department letter of even No. 99 dated 07.01.2013 (Copy enclosed). Therefore, you are advised to submit point-wise compliance of shortcomings already issued vide this department letter dated 07.01.2013 for further consideration in this matter.

Yours Faithfully


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

01c
01y

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI - 1

C-9 C/4

8

No. F-1/DFSI/MS/1243/194

Dated 7/1/2013

To

The Principal

M.C.D. Primary Boys/Girls School
E-Block, Sultan Puri
Delhi

Subject: Regarding fire safety certificate in M.C.D. Primary Girls/Boys School, E-Block Sultan Puri Delhi.

Sir,

Please refer to your letter No. nil dated 23/8/12

on the subject cited above. In this connection this is to inform you that the inspection of the above said premises was carried out by the officer concerned of this department along with school authority on 03/12/12 from fire safety point of view and following shortcomings were observed:

1. Fire extinguishers are not adequate, provide 6 nos more extinguishers of ABC/62 type (2.5kg).
2. Pump Cap. 450 cfm, 40 mts head, 10000 ltr. water tank on Terrace and fire hose reel at each floor not provided.
3. Stair case not adequate, provide one more stair case 1st to second floor width 1.5 mts.
4. All Class Rooms required two doors width 1.0 mts. each.

8 _____
9 _____
10 _____

Keeping in view of the above Fire safety certificate cannot be considered at this stage. You are requested to provide the fire safety arrangements as per the circular of Director of Education, issued vide letter No. F-16/estate/cc/fire safety/2011/3298-3398 dated 01/03/2011

Yours Faithfully

Copy to The Addl. Director (Ed)
North M.C.D.
Civic Centre
Minto Rd. N. Delhi

31/12/12
Dy. Chief Fire Officer
Delhi Fire Service
dl