

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F6/DFS/MS/School/WZ/2022 /202

Dated: 04/05/2022

To,

The Principal,
M.S. Memorial Public School,
E-106, Saini Vihar, Laxmi Park,
Nangloi, Delhi-110041.

Sub. :-Renewal of Fire Safety Certificate in r/o M.S. Memorial Public School, Located at E-106, Saini Vihar, Laxmi Park, Nangloi, Delhi-110041.

Sir,

Please refer to your email dated 09.03.2022 on the subject cited above. In this connection, it is to inform you that the said School building has been inspected by the officer concerned of this department on 11.04.2022 in presence of Sh. Rajeev Saini (Owner). During inspection, it has been observed that the said building is comprised of Ground + 03 Upper floor served with 03 Staircases. Fire safety arrangement such as, fire extinguisher, first aid hose reels, fire pumps & overhead water tank capacity etc. have been found provided. However, the following points have been noticed as shortcomings.

1. Overhead water tank 10,000 ltrs. capacity is provided but domestic use connection to be removed.
2. One room constructed at terrace shall be removed.

In view of the above shortcoming, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Education Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to:-

1. The Director, Directorate of Education Old Secretariat Delhi – 110054.