

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2022/ 203

Dated: 04/05/2022

To,

The Principal,  
P. D. Model Sr. Sec. School,  
88, Paschimi Friends Enclave,  
Sector-6, Sultan puri Road,  
Delhi-110086,

**Sub:** Issue of FSC in r/o P. D. Model Sr. Sec. School located at 88, Paschimi Friends Enclave, Sector-6, Sultan puri Road, Delhi-110086.

Sir,

Kindly reference to online e-mail dated 01.02.2022, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **11.04.2022**, in presence of **Sh. Ashu (Manager)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Terrace pump of 450 lpm provided but not functional.
2. 2000 ltrs Over Head water captive tank provided against the required capacity of 10,000 ltrs.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:  
[http://www.delhi.gov.in/wps/wcm/connect/doiit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htp://www.delhi.gov.in/wps/wcm/connect/doiit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htp://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms)

Yours faithfully

  
(Dhrampal Bhardwaj)  
Dy.Chief Fire Officer  
Tel;-01123414250

OK  
NY