

28

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2022/SZ/313

Dated 04/05/2022

To

The Dy. Health Officer, (SDMC)  
Public Health Officer, (Green Park Zone)  
Aurobindo Marg, Green Park, Delhi 110016

**Sub:** - Regarding issuance of fire safety certificate in r/o M/s RIZQ Restaurant, (A Unit of SHR Hospitality) located at 3<sup>rd</sup> Floor Plot No- D-12 Defence Colony, New Delhi 110024.

Sir,

This has reference to your **MHA Portal ID No. 2022040605859** dated **06/04/2022** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 21.04.2022 in the presence of Mr. Ajay Giri to verify the fire safety measures installed in the building and observed that building is comprised of Basement + Stilt, Ground and 03 upper floors, but restaurant running at Third Floor only. During inspection, following points were observed:

1. The exit found provided 1.20 mtr and 1.20 mtr wide against the requirement of 1.50 mtr each.
2. As per the clause 7.8.3 of UBBL-2016m exit shall be place as remote from each other as possible and shall be arranged to provide direct access in separate direction from any point in the area served. Further exits shall be so arranged that they may be reached without passing through another unit i.e. through kitchen & occupied area.
3. Fire fighting pumps is provided but not on auto mode.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

  
(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

