

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No.F6/DFS/MS/School/2022/NDZI/199

Dated: 04/05/2022

To,

The Principal  
Shibban Modern Secondary School,  
Vijay Colony, New Usmanpur,  
Delhi-110053.

**Subject: -Regarding issuance of Fire Safety Certificate in r/o Shibban Modern Secondary School located at Vijay Colony, New Usmanpur, Delhi-110053.**

Sir,

With reference to your email shibban.shibban.school75@gmail.com dated 19/04/2022 on the subject cited above. Delhi Fire Service had already issued shortcomings vide letter No. F6/DFS/MS/School/2021/80 dated 17/02/2021.

Copy of the same is enclosed for your ready reference.

Yours faithfully



(Dr. S. K. Tomar)  
Dy. Chief Fire Officer

Copy to:-

The Dy. Director of Education  
B-Block, Yamuna Vihar,  
New Delhi-110053

461

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No.F6/DFS/MS/School/2021/ 80

Dated 17/02/2021

To,  
The Principal,  
Shhibban Modern Secondary School,  
Vijay Colony, New Usmanpur,  
Delhi-53.

**Sub:- Request for issuing a Fire Safety Certificate.**

Sir,

With reference to your letter No. Ref.No. Smsps/2020/338 dated 24/11/2020 & letter No. F/6/DFS/MS/School/2020/NDZ/611 dated 04/09/2020 issued by this department on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view on dated 14/01/2021. The School building comprises of ground plus two upper floors. During the course of inspection following observation was made:-

1. The premises is not accessible to fire engines.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage.

Yours Faithfully,



(Dr. S. K. Tomar)  
Dy. Chief Fire Officer

Copy to:-

The Joint Director of Education,  
(land & Estate)  
Director of Education,  
Lacknow road, Delhi-54

