

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE; NEW DELHI-110001

No. F-6/DFS/MS/School/2022/201

Dated 04/05/2022

To,

Swami Vivekananda Public School
Block-A, Gali No.08, Amrit Vihar,
Burari Delhi-110009.

Sub: - Regarding issuance of fire safety certificate in r/o Swami Vivekananda Public School at Block-A, Gali No.08, Amrit Vihar, Burari Delhi-110009.


Sir,

Please refer to your letter no. S.V.P.S.292/2022-23 Dated: 07.03.2022 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 31.03.2022 at the time of inspection Mrs. Sheuli Goshal (Principal) was also present at site. During the course of the inspection it is observed that the building is comprised of Ground & 02 upper floors only. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

- 1 Hose reel hose provided but not functional.
- 2 Terrace level fire pump capacity of 450lpm found removed.
- 3 Terrace level fire water tank capacity of 10,000ltr provided empty.
- 4 Exit signage's found removed at some places.

Keeping in view of above, fire safety certificate cannot be considered at this stage

Yours faithfully



(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph.-011-23414250

b/c

Copy to:-

1. The Director of Education, Government of N.C.T of Delhi. Old Seett. Delhi - 110054.