

D
C-41

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6.DFS/MS/GH/2022/SZ/317
To

Dated: 29.04.2022

The Joint Commissioner of Police,
1st Floor, P.S Defence Colony
New Delhi 110049.

Sub: Issuance of No Objection Certificate in r/o The Ambica Palace, Guest House, Situated at A-1/300 Safdarjung Enclave, New Delhi 110029.


Sir,

This is in reference with MHA Portal ID 2022033104777 dated 01/04/2022 on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 23.04.2022 in the presence of Mr. S. K Chaddha of the Guest House. During the inspection, it was observed that the Guest House is running Basement, Ground + Three Upper Floors. The shortcomings observed are as below:

1. Fire check doors not provided in the building as per clause 7.31 of UBBL 2016.
2. Smoke management system not provided as per clause 7.31 of UBBL 2016.
3. Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.
4. Fire fighting pumps is not on auto mode.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



**(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)
DELHI FIRE SERVICE**

Out