

N/

C91

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

NO. F. 6 / DFS / MS / GH / 2022 / 315

Dated. 29/04/2022

To,

The Joint Commissioner of Police (Lic/Branch)
1st Floor, P.S Defence Colony,
New Delhi 110049

Sub: -Regarding issuance of fire safety certificates in r/o The Gera's Guest House at G- 66B
Kalkaji New Delhi- 110019

Sir,

This has reference with MHA Portal ID 202040205216 Dated 02/04/2022 on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 20/04/2022 in the presence of Mr. Aftab (Manager) of the Guest House. During the inspection, it was observed that the building comprised of Ground + 04 Upper Floor. The shortcomings observed are as below:

1. There is a 4th floor of the building. As per the notification dated 27/05/2019 fire NOC for guest House will not be issued to those building, which have occupancy more than four floors (excluding basement & stilt floor)

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.


(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)
DELHI FIRE SERVICE

