

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F.6/DFS/MS/BP/2022/ *hospital/982*

Dated: *04/05/2022*

To,

Dr. R. N. Das,  
Medical Superintendent Nursing Home,  
Government of National Capital Territory, Delhi,  
Directorate General of Health Services,  
Nursing Homes Cell, 3<sup>rd</sup> Floor, DGD Building,  
S-1, School Block, Shakarpur, Delhi-110092

Sub:- Fire NOC from Delhi Fire Service in r/o Vinayak Hospital, 2, Derawal Nagar, Model Town, Delhi-110009


Sir,

With reference to your letter no. F.24/969/NW/NH/DHS/HQ/2020-23/662 dated 11.04.2022 on the subject cited above; it is informed that the referred building plans in respect of existing construction of Institutional Building at Vinayak Hospital, 2, Derawal Nagar, Model Town, Delhi-110009 have been scrutinized from fire and life safety point of view and following shortcoming were observed:-

1. The year of change of use/occupancy & construction of additional floor along with relevant record is not provided.
2. Section/elevation of the building is not provided.
3. Alternate staircase is not provided. Width of the staircases in basement is also not provided.
4. The schedule of doors is not provided.
5. The fire prevention and fire safety measures are not duly marked in the plan.
6. Lift lobby is not provided.
7. Segregation of staircase is required to be provided.

In view of the above, the building plans are rejected with a request to resubmit plans after rectification of above shortcoming for further consideration.

Yours faithfully,

  
*4/5/2022*  
(Virendra Singh)  
Chief Fire Officer

Copy to:-

1. The Executive Engineer (Bldg.) HQ,  
North Delhi Municipal Corporation,  
8<sup>th</sup> Floor, Minto Road,  
New Delhi.