

E-42

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001

No. F6/DFS/MS/11/2021/SZ/ 594

Dated 29/12/2021

To,

Sh. Ashish Malhotra,  
M/s Fly Bar Eating House J-2/11, Third Floor,  
B.K. Dutt Market, Rajouri Garden, New Delhi-110027.

Sub: - Regarding grant of NOC from fire safety point of view in r/o M/s Fly Bar (a unit of at the top Hospitality) J-2/11, 3<sup>rd</sup> Floor, B.K. Dutt Market, Rajouri Garden, New Delhi-110027.


Sir,

Please refer to your letter no. ID No. 2021090520265 dated 27/10/2021 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department have carried out the inspection of the above-mentioned assembly building from fire safety point of view. At the time of inspection Sh. Ashish Malhotra (owner) was present and it was observed that the building is comprised of basement, ground plus three upper floors but restaurant is running at third floor only. During the course of inspection, the following points / shortcomings were noticed:

1. Both the staircases should be of 1.5 m wide. At present there are two staircases of 1.5 & 1 meter.

In view of above, the assembly building cannot be considered for grant of fire safety certificate at this stage. Therefore you are suggested to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours faithfully

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to:-

1. The Joint Commissioner of Police, Licensing Unit, First Floor, Police Station, Defence Colony, New Delhi.