

250

251

04/05/2022

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001

NO. F6/DFS/MS/SZ/2022/GH/324

DATED: 04/05/2022

To,

The Addl. Commissioner of Police,
Licensing Unit 1st Floor,
P.S Defence Colony,
New Delhi-110049.

Subject: Issuance of Fire safety Certificate in r/o Hotel Marrigold (A unit of RSJ Banquets),
Located at Plot No – 11, Sector-10, Dwarka, New Delhi-11075.

Sir,

Please refer to online application no 2022032304019 dated 24/03/2022 on the subject mentioned above. In this connection it is to inform you that the above said premises was visited by the team of officers concerned of this department on 12/04/2022 in presence of Sh. Sanjeev Malhotra to see the compliance of the shortcomings communicated vide this office letter no. F.6/DFS/MS/GH/2013/SZ/2475 dated 30/10/2013 (Copy enclosed) to Nimal guest house earlier running in same premises and found that the shortcomings are still not complied.

Apart from this it is also noticed that the width of corridors are 1.10 m against required width 1.8 m.


You are requested to comply all the shortcomings communicated vide above refer letter and extend the width of corridors up to 1.80 m at all the floors.

The premise shall be on the risk & cost of owner / management till the compliance of shortcomings.

In view of the above FSC from fire safety point of view cannot be considered at this stage.

Yours faithfully,

Enclose:- As above


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Dy. Health Officer, Najafgarh Zone, SDMC Building, Dhansa Stand, Najafgarh, New Delhi-110054.
2. The Manager Hotel Marrigold (A unit of RSJ Banquets), Located at Plot No – 11, Sector-10, Dwarka, New Delhi-11075.