

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI – 110001**

No.F6/DFS/MS/School/SZ/2022/212

Dated: 09/05/2022

To

The Principal,  
Terrasa Public School,  
C-142-143, Tigri Extn, New Delhi-62.

**Sub:-** Regarding renewal of Fire Safety Certificate in r/o **Terrasa Public School located at C-142-143, Tigri Extn, New Delhi-62.**

Sir,

With reference to your letter no. nil dated 02.03.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 06.04.2022 in the presence of Mr. Rajesh Chauhan, owner and it was observed that the school building is comprised of Ground + 01 upper floors. During the inspection following shortcomings were observed:-

1. The available road width is less than 5.0 mtrs against the minimum road width requirement of 6.0 mtrs.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
**(Sunil Chawdhary)**

Dy. Chief Fire Officer  
Delhi Fire Service

**Copy to:-**

The Dy. Director of Education, GNCT of New Delhi DISST, South Block-C, Defence Colony, New Delhi-24.