



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/2022/NDZ/209

Dated: 09/05/2022

To
Authorized Signatory,
The Sacred Hearts Public School, South Anarkali,
Delhi-110051.


**Sub.:- Regarding issuance of Fire Safety Certificate in r/o The Sacred Hearts Public School,
South Anarkali, Delhi-110051.**

Sir,

With reference to your Letter No. Nil dated 18/02/2022 on the subject cited above, in this connection it is to inform you that school premises was visited by the officer's concerned of this department on dated 26/04/2022 in the presence of Sh. Nitin Sharma and observed that now building comprised of Ground, Mezzanine, 1st floor, 2nd floor and 3rd floor but the school have been issued FSC by this department vide letter no. F6/DFS/MS/2006/2213 dated 25/08/2006 for Ground and Two upper floors only. Hence this is a case of addition/alteration.

In view of above you are requested to submit sanctioned plan / as built plans on the scale of 1:100 having details of height/covered area, year of construction/conversion of occupancy duly marked with fire and life safety arrangements as stipulated under Rule 33 of Delhi Fire Service Act of rules 2010 through building/local authority.

Yours faithfully,


(ATUL GARG)
Director

