

C50

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/GH/NDZ/2022/332

Dated: 06/05/2022

To

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

**Sub:** Regarding renewal of Fire Safety Certificate in respect of **M/s Shani Niwas Guest House** located at **159, Kucha Ghasi Ram, Fatehpuri, Delhi.**

Sir,

With reference to online application I.D. no. 2022040105013 dated 01.04.2022 on the subject cited above, it is informed that the guest house was inspected by Assistant Divisional Officer (SPM) from this department on 18.04.2022 in the presence Mr. Parmod Soni (Owner) and it was observed that building is comprised of Ground + 03 upper floors. During inspection, following shortcomings were observed:

1. Fire check door not provided as required per gazette notification dated 27.05.2019.
2. CO detectors not provided as required per gazette notification dated 27.05.2019.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
01/05/22

**(Dr. S.K. Tomar)**  
Dy. Chief Fire Officer  
Tel: 011-23412025

**Copy to:-**

The Licensee,  
Shani Niwas Guest House at 159, Kucha Ghasi Ram, Fatehpuri, Delhi.

82  
6/5