

C-29

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI – 110001

No. F6/DFS/MS/GH/NDZ/2022/333

Dated: 06/05/2022

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of **M/S Ashirwad Inn Guest House**, located at **70-71, Church Mission Road, Fatehpuri, Delhi – 110006**.

Sir,

With reference to online application I.D. no. 2022041507096 dated 15.04.2022 on the subject cited above, it is informed that the guest house was inspected by Assistant Divisional Officer (SPM) from this department on 28.04.2022 in the presence of Mr. Bacchan Singh (Manager) and it was observed that building is comprised of Ground + 03 upper floors (Guest rooms only at 3rd floor). During inspection, following shortcomings were observed:

1. Fire check door not provided as required per gazette notification dated 27.05.2019.
2. CO detectors not provided as required in Gazette Notification dated 27.05.2019.
3. First Aid Hose reel found non functional.
4. Fire pump not in auto start mode.
5. Exit Signage not adequately provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Dr. S.K. Tomar)

Dy. Chief Fire Officer

Tel: 011-23412025

Copy to:-

M/S Ashirwad Inn Guest House, located at 70-71, Church Mission Road, Fatehpuri, Delhi – 110006.

84/6/5