

e.5

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2022/SZ/ 320

Dated 10/10/2022

To

The Dy. Health Officer, SDMC,
Public Health Department,
South Zone, Aurobindo Marg,
Green Park, Delhi 110016

Sub: - Regarding issuance of fire safety certificate in r/o M/s BOTTLE HOUSE (A Unit of Tank Hospitality) located at Plot No 4 & 5 Ground Floor, Satya Niketan City, New Delhi 110021.

Sir,

This has reference to with MHA Portal ID 2022030703185 dated 08/03/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 30.04.2022 in the presence of Mr. Rohit Kumar to verify the fire safety measures installed in the building and observed that the building is comprised of ground + 04 upper floors and the restaurant is running at Ground floor only. The height of the building mentioned in the online portal application form is 11 meters and it seems to be wrong as the building is comprised of ground plus 04 upper floors.

1. There are two exits having width of 1.50 mtr & 1.40 mtr against the required width of 1.50 mtr each. The rear side exit door/ escape route is through kitchen area which is not acceptable.
2. The First aid hose reel not provided.
3. Manual Operated Electrical Fire Alarm system not provided.
4. The Internal Hydrant is not provided.
5. Terrace level pump capacity 450 LPM not provided.
6. Overhead water storage tank for firefighting purposes capacity 20,000 ltrs not provided.
7. Exit signage's not provided.
8. The standby power supply not provided.
9. Two sets of building sanctioned plans/ completion plans showing height of the building is required to verify the height of the building.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Joint commissioner of Police, Lic/Branch, 1st Floor P. S Defence Colony, New Delhi 110049.