

C55

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/GH/NDZ/2022/ 337

Dated: 10/05/2022

To

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

**Sub:** Regarding renewal of Fire Safety Certificate in respect of **M/S Friends Guest House** located at **5220, Gali Kumharan, Ballimaran, Chandni Chowk, Delhi.**

Sir,

With reference to online application I.D. no. 2022040705953 dated 07.04.2022 on the subject cited above, it is informed that the guest house was inspected by Assistant Divisional Officer (SPM) from this department on 26.04.2022 in the presence Mr. Murtaza (Manager) and it was observed that building is comprised of Ground + 03 upper floors. During inspection, following shortcomings were observed:

1. First Aid Hose reel found non functional.
2. Fire pump not in auto start mode.
3. Fire extinguisher not adequately provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



**(Dr. S.K. Tomar)**  
Dy. Chief Fire Officer  
Tel: 011-23412025

8/5  
9/5

**Copy to:-**

M/S Friends Guest House at 5220, Gali Kumharan, Ballimaran, Chandni Chowk, Delhi.