

C-69

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2022/ 328

Dated: 06/05/2022

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of **M/s Rest Inn** located at **3938, Urdu Bazar, Jama Masjid, Delhi.**

Sir,

With reference to online application I.D. no. 2022021602264 dated 16.02.2022 & email dated 19.04.2022 on the subject cited above, it is informed that the guest house was inspected by Assistant Divisional Officer (SPM) from this department on 22.04.2022 in the presence Mr. Mohhamad (Manager). During inspection, following shortcomings were observed:

1. Fire check door not provided as required per gazette notification dated 27.05.2019.
2. CO detectors not provided as required in gazette notification dated 27.05.2019.
3. First Aid Hose reel found non functional.
4. Rooms at terrace floor and above 3rd floor are not allowed as per gazette notification dated 27.05.2019.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Tel: 011-23412025

Copy to:-

The Licensee, M/s Rest Inn at 3938, Urdu Bazar, Jama Masjid, Delhi.

8/5/22