

=10  
C-5

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No. F.6/DFS/MS/GH/NDZ/2022/

Dated: 06.05.2022

To

The Deputy Commissioner (Licensing)  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

Subject:- Online Application ID No.- **2022032804344** in r/o **The Chaitanyas** situated at A-12, Main Road Ghazipur, Delhi - 110096.


Sir,

This has a reference to online application ID No.- **2022032804344** dated 03.03.2022 received on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 08.04.2022 in the presence of Mr. Nizam (Manager) and observed that building comprised of basement (store) + ground (closed) + 03 upper floors, 1<sup>st</sup> floor (shops) and Guest House at 2<sup>nd</sup> & 3<sup>rd</sup> floor and following shortcomings were observed at site.

1. Staircase of width 1.4 & 1.5 mtr. provided against required 02 nos. of 1.5 mtr.
2. Fire check door not provided.
3. Carbon Monoxide detectors not provided.
4. MOEFA not provided.
5. PA system not provided.
6. Sprinkler not provided in basement.
7. Overhead water tank capacity of 7,000 liters provided against required capacity of 10,000 liters not provided.
8. Exit Signage not adequate.

In addition to above the application needs correction in respect of height of the building, number of the specific floor and floor wise occupancy, width of staircase, width of door and width of corridor. Accordingly, the applicant may be directed to furnish correct information. In view of above, shortcomings, the applicant for issuance **Fire Safety Certificate is rejected**. The occupancy of the building/premises in absence of requisite Fire Safety arrangements shall be at the risk and liability of the owner/occupier. Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to:-

The Manager,  
The Chaitanyas,  
A-12, Main Road Ghazipur, Delhi - 110096.