

025

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2022/*School/218*

Dated: 13/05/2022

To,

Smt. Radha Ghai (Principal) <greatmission.education@gmail.com>
Great Mission Public School,
D-40, Sanjay Enclave,
New Delhi – 110059.

Subject: Renewal of Fire Safety Certificate in r/o Great Mission Public School, Located at D-40, Sanjay Enclave, New Delhi – 110059.

Sir,

Please refer to your letter no. GMPS/F/DFS/22/146 Dated - 21/03/2022 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 11-04-2022 in presence of Smt. Radha Ghai (Principal) for fire safety point of view.

During the course of inspection the flowing shortcomings are noticed.

1. Hose reel hose found nonfunctional.
2. Terrace pump of 450 lpm found nonfunctional.
3. Tin shed found erected at terrace.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,



(Sunil Chaudhary)
Dy. Chief Fire officer
Delhi Fire Service

Copy to:-

1. Directorate of Education Old Secretariat Delhi – 110054

Handwritten initials and date: 13/05/22