GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI <u>HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001</u>

No.F.6/DFS/MS/2022/WZ/ 1058

Dated /3 / 05/2022

To,

Sh. Randhir Arora (Vice President), WMOWA Pearls Corporate ("W" Mall) Plot No.9, Manglam Place, Sector-03, Rohini, New Delhi-110085.

Sub: Issue of FSC in r/o. M/s Pearls Corporate ("W" Mall), Plot No.9, Manglam Place, Sector-03, Rohini, New Delhi-110085

Sir,

This is in reference to your letter No. nil dated 11.03.2022 received through outdoor diary no. 7277 dated 14.03.2022 on the subject cited above. The premise was inspected by the concern nominated authority of this department on 27.04.2022, in presence of Sh. Randhir Kr. Arora (Vice President) to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Internal hydrant & Automatic Sprinkler System in basement provided but main line found ruptured during inspection & testing.

In view of NOC is rejected and you will run the mall at your own risk.

Yours faithfully

DIRECTOR Ph; 011-23414000

Olt Olt

0-0 13

**** . ₽