

C 20

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/School/SZ/2022/ 221

Dated: 13/05/2022

To

The Principal,
Pragati Nursery School,
Pocket 10-A, Jasola, New Delhi-25.

Sub:- Regarding renewal of Fire Safety Certificate in r/o **Pragati Nursery School**, located at **Pocket 10-A, Jasola, New Delhi-25.**


Sir,

With reference to email letter dated 13.01.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 20.04.2022 in the presence of Mr. Ramanand Chaudhary, Supervisor and it was observed that the building is comprised of Basement + Stilt + Ground + 2 upper floors. During the inspection following shortcomings were observed:-

1. Alternate staircase shall have min. width of 1.25 meters instead of available width of 1.0 mtr.
2. All water based fire protection systems were found non functional due to unavailability of power.
3. Fire pump of discharge of 1620 LPM shall be provided instead of available fire pump having discharge of 900 LPM.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Sunil Chawdhary)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.

of 02/5