

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2022/230

Dated: 17/05/2022

To,

The Principal, <adarshworldschool@gmail.com>
Aadarsh World School,
Sector-12, Phase – 1, Dwarka,
New Delhi – 110075

Subject: Renewal of Fire Safety Certificate in r/o Aadarsh World School Located at Sector-12, Phase – 1, Dwarka, New Delhi – 110075.

Sir,

Please refer to your letter no AWS/dwk/2022-23/443 Dated 20/04/2022 on the subject mentioned above. In this connection it is to inform you that the premises was re inspected by the officer concerned from this department on 04/05/2022 in the presence of Sh. Karan Singh (Physical Education Teacher).

During the course of inspection following shortcomings are observed.

1. Hose reel hoses & Hydrants found non functional.
2. Terrace Pump found non functional.
3. School activities are noticed in basement separately constructed below the stage without taking any fire and life safety measures.
4. Exit Signage found removed from some places.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,



(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service.

Copy to:- Directorate of Education Old Secretariat Delhi – 110054.

17/05-0/c