

55
c-60

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2022/352

Dated: 17/05/2022

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding suspension of Fire Safety Certificate in respect of **M/s Al-Gulzar Guest House** located at 4092-93, **Nal Wali Gali, Urdu Bazar, Jama Masjid, Delhi.**


Sir,

This is in reference with our notice (for entry and inspection under section 33(1) of the DFS act) dated 27.04.2022. The premises was inspected by the concerned nominated authority of this department on 27.04.2022 in the presence of Mr. Mohammed Arshi. During inspection following shortcoming were found:

1. CO detector & FCD not provided as per gazette notification dated 27.05.2019.
2. Overhead water storage tank provided of 3,000 Ltrs. against the requirement of 5,000 Ltrs.
3. Fire pump of capacity 450 LPM found removed.

In view of above, the Fire Safety Certificate issued vide letter no. F6/DFS/MS/GH/NDZ/2021/76 dated 05.02.2021 shall remain suspended till the shortcomings mentioned above are not rectified.

Yours faithfully,


12/5/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Tel: 011-23412025

Copy to:-

Dy. Health Officer, North Delhi Municipal Corporation, Civic Centre, JLN Marg, New Delhi.

84
12/5 5