

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI – 110001

No.F6/DFS/MS/School/SZ/2022/224

Dated: 17/05/2022

To

The Principal,
Bharat Public School,
J-1/10, Saurabh Vihar,
Near Shiv Mandir (Jaitpur), New Delhi.

Sub:- Regarding renewal of Fire Safety Certificate in respect of **Bharat Public School located at J-1/10, Saurabh Vihar, Near Shiv Mandir (Jaitpur), New Delhi.**

Sir,

With reference to your letter no. BPS/04/110 dated 18.04.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 02.05.2022 in the presence of Mrs. Alka Verma (Principal) and it was observed that the building is comprised of ground + 03 upper floors. During the inspection following shortcoming were observed:-

1. School is not accessible to fire engine as approach road width is less than 6.0 meters.
2. An additional staircase of 1.50 meters shall be provided to meet the dead end distance requirement of less than 6.0 meters.
3. Fire extinguishers found not provided.
4. First aid hose reels found not provided.
5. Fire pump having capacity 450 LPM found not provided.
6. Overhead tank capacity 10,000 liters (exclusively for firefighting) found not provided.
7. Exit signages found not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)

Director

Delhi Fire Service

Copy to:-

The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.

c/c Ate
13/5