

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F6/DFS/MS/School/2022/NDZ/ 226

Dated 17/05/2022

To,

The Principal,
East Delhi Nigam Pratibha Vidyalaya
E-Block, Nand Nagri,
Delhi-110093

Sub:- Regarding Issuance Fire Safety Certificate in East Delhi Nigam Pratibha Vidyalaya E-Block, Nand Nagri Delhi-110093.

Sir,

With reference to your letter No. nil dated 27/04/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned school from fire safety point of view on dated 09/05/22 in presence of Mr.S.S.Gond, Principal of the School. The following points / shortcomings were noticed in the building comprised of ground plus two upper floors .

1. First Aid Hose Reels not functional.
2. A fire pump having 450 LPM output at 40 meters head not provided.

In view of above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)
Director

Copy to:-

The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi 92