

214

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/Restaurant/2022/NDZ/ 330

Dated: 13/05/2022

To

M/s Hira Sweets and Namkeen
Shop no. 16657-58, Old No. 1157,
Gali -5, Vill.- Vidhanpur, East Rohtas Nagar,
Babarpur, Shahdara, Delhi-110032.

Sub.:- Regarding issuance of Fire Safety Certificate in r/o M/s Hira Sweets and Namkeen, Shop no. 1,6657-58, Old No. 1157, Gali -5, Vill. - Vidhanpur, East Rohtas Nagar, Babarpur,Shahdara, Delhi-110032.

Sir,

With reference to your online application No. 2022040605822 dated 07/04/2022 on the subject cited above, in this connection it is to inform you that premises was inspected by the officers concerned of this department on dated 26/04/2022 in the presence of Sh. Sushil, (Manager) and observed that building comprised of ground plus three upper floors but eating house (sweet shop) is proposed on ground, first and second floor. Following shortcomings were observed during the time of inspection.

1. 01 number of Staircase having width 1.13m is provided against requirement 2 number of staircases of 1.50 m width each.
2. 01 door of width 1.13 m is provided against requirement of 2 number of doors of 1.50 m width each.
3. First Aid Hose reel is not provided.
4. MOEFA is not provided.
5. Down-Comer is not provided.
6. A Fire pump having 450 lpm output of 40 meter head at terrace is not provided.
7. Over head tank 25,000 liters is not provided.
8. Exit signage are not provided.

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR

Copy to:-

The Joint Commissioner (Lic.), 1st Floor Police Station, Defence Colony,
New Delhi-49.

okd