

5.12
e50

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

F6/DFS/MS/GH/SZ/2022/ 347

Dated: 13/05/2022

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station, Defence Colony,
New Delhi.

Ref: Online application no. 2022040906356

Sub: Regarding renewal of Fire Safety Certificate in respect of **M/s Ikon Residency (Guest House) located at D-823, New Friends Colony, New Delhi-65.**


Sir,

With reference to the online application no. 2022041607272 dated 09.04.2022 on the subject cited above, it is informed that the said Guest House was inspected by the officer concerned of this department on 19.04.2022 in presence of Mr. Manoj manager and it was observed that the building is comprised of Basement, Ground + 03 upper floors & terrace floor having 01 staff room. Following shortcomings were observed during the inspection:

1. Hose reel found non functional.
2. CO detector as required in gazette notification dated 27.05.2019 not provided.
3. Manually operated electrical fire alarm system (MOEFA) found non functional.
4. Automatic sprinkler system found non functional in basement.
5. Fire Pump found non functional
6. Exit & lift Signages found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Local Authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours Faithfully



(Sunil Chawdhary)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

The Licensee, M/s Ikon Residency (Guest House) located at D-823, New Friends Colony, New Delhi-65.

etc B/L
10/5/22