

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/CNG/2022/SZ/ 1037

Dated: 11 / 05 / 2022

To

Sh. Ajay Khatri, DGM-(Fire & Safety)  
(IGL) LGL Bhawan, Plot No 4,  
Community Centre, R. K Puram,  
Sector- 09, New Delhi 110049

Sub: Regarding issuance of Fire Safety Certificate in r/o Indraprastha Gas Ltd, Retail Outlet (CNG Pump) at Sunehari Pullah DIMTS Bus Depot

Sir,

This is in reference to with IGL/F&S/2022/15/134/1 Dated 06-04-2022 on the subject cited above. The premise was inspected by the concern nominated authority of this department in presence of Mr. Sandeep Kumar (Technician) dated 26-04-2022 & to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. First Aid Hose Reel not provided.
2. MOEFA Not provided.
3. Fire fighting terrace level pump of capacity 450 LPM not provided.
4. Overhead tank capacity 10,000 ltrs not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(ATUL GARG)  
DIRECTOR

**DELHI FIRE SERVICE**