

C13

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/EH/WZ/2022/329

Dated: 13/05/2022

To,

Joint Commissioner of Police,
Licensing Unit, 1st floor,
Police Station, Defence Colony, New Delhi.
E-Mail - Addcp.lic@delhipolice.gov.in.

Sub: - Inspection report in r/o M/s. Kay Aar Hospitality (A unit of Dhaba Estd -1986 Delhi)- SH,2F 12, Second Floor, Pacific Mall, Khayla New Delhi.

Sir,

Please refer to your online application no.:2022040105043 dated 04/04/2022 received through MHA portal, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 28/04/2022 in the presence of Sh. Dilip Kumar (Manager) to check the shortcomings already issued by this department vide letter No.F6/DFS/MS/WZ/EH/2022/180 dated 11/02/2022.

The Status of shortcomings are as under:-

S.N.	Shortcomings	Status
1.	Two Exit doors having width 1 X 1.75 mts & 1 x 1.45 mts are provided against the required width of 1.50 mts each.	Not Rectified
2.	Exit Signage's are not provided.	Rectified
3.	2 nd exit is passing through kitchen.	Not Rectified
4.	Access corridor to the alternate exit is less than required width (1.5 mts).	Not Rectified

In view of above Shortcomings, the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety Arrangements Shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully


(Atul Garg)
Director

Delhi fire service

Copy to: -

1. The Owner/Occupier of Kay Aar Hospitality (A unit of Dhaba Estd -1986 Delhi)- SH,2F 12, Second Floor, Pacific Mall, Khayla New Delhi.
2. DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi- 110027. (dhwestzone@gmail.com)


10/5/2022

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/WZ/EH/2022/180

Dated: 11/02/2022

To,

The Joint Commissioner of Police,
 Licensing Unit, 1st floor, Police Station,
 Defence Colony, New Delhi.
adlcp.lic-dl@nic.in

Sub: - Inspection report in r/o M/s. Kay Aar Hospitality (A unit of Dhaba Estd -1986 delhi)- SH,2F 12, Second Floor, Pacific Mall, Khayla New Delhi.

Sir,

This is in reference to the online application received through MHA portal vide ID-2021122829490 dated 14/01/2022, regarding issuance of Fire Safety Certificate in respect of aforesaid restaurant. In this connection, it is to inform you that the premises was inspected by officers concerned of this department on 02/02/2022 in the presence Sh. Nirdosh saren to check the fire safety arrangements provided in the building.

During the course of inspection, it was observed that the said restaurant is running at Second floor of Pacific Mall comprised of 02 tier basements, ground plus four upper floors and projection room. Fire safety arrangements of the restaurant are interlinked with Mall's fire safety system. However, following shortcoming was observed: -

1. Two Exit doors having width 1 X 1.75 mts & 1 x 1.45 mts are provided against the required width of 1.50 mts each.
2. Exit Signage's are not provided.
3. 2nd exit is passing through kitchen.
4. Access corridor to the alternate exit is less than required width (1.5 mts).

In view of above Shortcomings the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisite fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully


 (Atul Darg)
 Director
 Delhi Fire Service

AT-1
 09/02/2022

Copy to: -

1. The Owner/ Occupier M/s. Kay Aar Hospitality (A unit of Dhaba Estd -1986 delhi)- SH,2F 12, Second Floor, Pacific Mall, Khayla New Delhi.
2. The DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi-110027.
 Email Id : - (dhowest_zone@gmail.com)