

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/NDZ2022/ 1059

Dated: - 13/05/2022

To

Sh. Yoginder Singh,
The Executive Engineer (Elect.),
EWM -101, Gate No 06, Jalebi Chowk, North Block,
New Delhi-110011.

Subject: - Regarding issuance of Fire Safety Certificate of North Block, New Delhi.

Sir,

This has reference to your letter no. AB (Misc)/DEM/101/2022/377 dated 11.03.2022, on the subject cited above. In this regard it is to inform you that the site was inspected by officers concerned of this department on 07.05.2022 in your presence of Sh. Mungi Krishan JE (E) and the following shortcoming were observed:-

1. Electrical shafts were not sealed horizontally and vertically properly.
2. Some fire extinguishers were found due for refilling.
3. Corridor found encroached by erecting temporary offices and gym near canteen which creating obstacles in movement of occupants and may also lead to fire hazards in case of emergency two occupancies are required to be segregated.
4. Hose reel and hydrant are not covering entire area of floors, need to enhance the length of hose reels or install new hose reels /hydrants to cover entire area.
5. Hoses found missing from hose boxes and some hose reels were also found nonfunctional.
6. PA system found nonfunctional.
7. Exit signages found inadequate
8. Lift signages "not to use lift in case of fire" are not provided.
9. LPG cylinders in canteen are required to be kept in LPG bank with proper fire protection.

However, complete inspection of the building couldn't be carried out due to restriction of the entry in the rooms/offices and budget press in the lower ground area.

Therefore, you are requested to rectify the above shortcomings and also inform us when the permission is granted to carry out the complete inspection of building.

Yours faithfully,


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

The Chief Architect, NDMC,
Deptt. of Architecture & Environs,
Palika Kendra, Sansad Marg, New Delhi.