

e-33

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/EH/WZ/2022/ 328

Dated: 13/05/2022

To,

Joint Commissioner of Police,
Licensing Unit, 1st floor,
Police Station, Defence Colony, New Delhi.
E-Mail - Addcp.lic@delhipolice.gov.in.

Sub: - Inspection report in r/o M/s Sahay Hospitality Located at Plot No. B -28, Ground Floor, Vishal Enclave, Rajouri Garden, New Delhi-110027.

Sir,

Please refer to your online application no.: -2021090920779 dated 31/03/2022 received through MHA portal, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 08/03/2022 in the presence of Sh. Yash pal Kumar to check the shortcoming already issued by this department vide letter No.F6/DFS/MS/EH/WZ/2021/442 dated 07/10/2021 & F6/DFS/MS/EH/WZ/2021/546 dated 30/11/2021.

The Status of shortcomings are as under:-

S.N.	Shortcomings	Status
1.	Width of exits are 1.70 & 1.13mts are provided against the requirement of 1.50 mts. each.	Not Rectified. The alternate exit is passes through the kitchen is not allowed.
2.	Over head water storage tank capacity 6000 ltrs is provided against the requirement of 20,000 ltrs.	Rectified (Using as domestic purpose)
3.	Exit signages are not provided at the palaces mentioned during inspection.	Rectified

In view of above Shortcomings the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety Arrangements Shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutorily authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully

(Anil Gung)
Director

Delhi fire service

Copy to: -

1. The Owner/Occupier of M/s Sahay Hospitality Located at Plot No. B -28, Ground Floor, Vishal Enclave, Rajouri Garden, New Delhi-110027.
2. DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi- 110027.