

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No.F6/DFS/MS/School/2022/ 232

Dated 18/05/2022

To

The Principal  
Sarvodaya Kanya Vidyalaya,  
GTB Nagar, Delhi-110009.

**Sub:** Regarding issuance of fire safety certificate in r/o Sarvodaya Kanya Vidyalaya, (I.D No.1309027), located at GTB Nagar, Delhi-110009.

Sir,

Please refer to your letter no. SKV/GTB/NAGAR/2022/160 dated 15.03.2022 and received in this office vide outdoor dairy no.7462 dated 22.03.2022 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 05.05.2022 to verify the fire safety measures issued vide NBC Part-IV and observed that as per earlier Fire Safety Certificate issued by this department letter of even no.1142 dated 29.05.2019 the building was comprised of two new blocks ground and 03 upper floors only. At the time of inspection Smt. Sangeeta Batra (Principal) was also present at site. During the course of inspection observations/ shortcomings made are as under:-

- 1 Fire extinguisher provided in the building but not functional.
- 2 Hose reel hose provided but not functional and some nozzle are missing.
- 3 Terrace level fire fighting pump capacity of 450lpm provided but not functional.
- 4 Terrace level fire water tank capacity of 10,000ltrs provided but found empty.
- 5 Exit signage's found removed at strategic locations in the building.

Keeping in view of above, fire safety certificate cannot be considered at this stage.

Yours faithfully



(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
Ph:-011-23414250

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.