

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/School/SZ/2022/225

Dated: 17/05/2022

To

The Principal,
Vatika Public School,
K-26, Saurabh Vihar, Jaidpur Road,
Badarpur, New Delhi-44.

Sub:- Regarding renewal of Fire Safety Certificate in respect of **Vatika Public School located at K-26, Saurabh Vihar, Jaidpur Road, Badarpur, New Delhi-44.**

Sir,

With reference to letter no. vps/2223/04/02 dated 23.04.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 02.05.2022 in the presence of Mr. Basant Kumar (Manager) and it was observed that the building which was earlier comprised of ground + 02 upper floor is now comprised of ground + 03 upper floors and hence is a case of addition/alteration. The fire and life safety requirements applicable are as prescribed in Unified Building Byelaws 2016 and National Building Code 2016 as per which following shortcomings were observed:-

1. School is not accessible to fire engine as approach road width is less than 6.0 meters.
2. Alternate staircase having width not less than 1.50 mtrs must be provided.
3. Fire extinguishers found non functional.
4. First aid hose reels found non functional.
5. Fire pump found non functional.
6. Overhead tank capacity 10,000 liters must be provided instead of available 6,000 liters.
7. Exit signages found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)

Director

Delhi Fire Service

e/c 13/5

Copy to:-

The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.