

e57

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/GH/NDZ/2022/355

Dated:- 17.05.2022

To,

The Manager,  
M/S Ved Dx. Guest House,  
3798-3800, Gali Ram Nath Patwa,  
Pahar Ganj, New Delhi.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Ved Dx. Guest House located at 3798-3800, Gali Ram Nath Patwa, Pahar Ganj, New Delhi.**

Sir,

This has reference to on-line ID no. 2022041106490 dated 11.04.22 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 09/05/2022 in the presence of **Manager** and following shortcomings were observed:

1. Smoke Management System are not provided as per gazette notification dated 27.05.2019
2. CO type detectors are not provided as per gazette notification dated 27.05.2019.
3. Hose reel found nonfunctional.
4. Pump not in auto start provision.
5. PA system found nonfunctional.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,



(Dr. S.K. Tomar)  
Dy. Chief Fire Officer  
Delhi Fire Service

**Copy to**

1. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony, New Delhi.