

HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

No. F6/DFS/MS/Educational/SZ/2022/ 1098

Dated: 18/05/2022

To,

Mr. Rahul Chaudhary,
New Delhi Institute for Information Technology & Management,
Plot No.-105, MOR-Pocket, Kalkaji,
New Delhi-110019

Sub: Renewal of Fire Safety Certificate in r/o New Delhi Institute for Information Technology & Management, Plot No.-105, MOR Pocket, Kalkaji, New Delhi-110019.

Sir,

This is in reference to your letter received through outdoor diary no. 330 dated 05/04/2022 on the subject cited above. The premise was inspected by the concern nominated authority of this department in presence of Mr. Rahul Chawdhary on 07/05/2022 to verify the compliance of fire prevention and fire safety measures required under the rules. The renewal of FSC is rejected under sub rule (3) of Rule 37, in the view of reasons mentioned below:

1. Fire Check Doors (FCD) of the basement found removed.
2. One electric driven pump of 1620 LPM discharge capacity with 60m head, a stand-by diesel driven pump of similar capacity and an electric driven Jockey pump of 180 LPM discharge capacity with 60m head along with Auto starting/Manual stopping found removed.
3. The auto starting of terrace pumps of both the blocks also not functional.
4. Exit signage/Lift signage/Floor landing signage found removed in both the buildings.
5. As the plans of the new block were not forwarded by the local authority as specified in section 2(q) of DFS Act-2007 to this department, you are requested to provide a set of completion plans (section, elevation & floor plans) of the new block for the record of this department.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours Faithfully


(ATUL GARG)
DIRECTOR

Copy to:

1. The Director, Directorate of Training and Technical Education, Muni Maya Ram Marg, Pitampura Delhi – 110034.
2. The Executive Engg.(Bldg.),SDMC, Jal Vihar, Lajpat Nagar, New Delhi-110024