

SERVICE: NEW DELHI-110001

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No.F6/DFS/MS/WZ/2022/ 1099

Dated: - 18 / 05 / 2022

To,

The Authorized Signatory,  
S. G. Engineers,  
Plot no. H-48, Udyog Nagar,  
Rohtak Road, Delhi-110041.

**Subject: Regarding renewal of Fire Safety Certificate in r/o S. G. Engineers. Located at Plot no. H-48, Udyog Nagar, Rohtak road, Delhi-110041.**


Sir,

This has reference to your letter no. nil dated nil on the subject cited above. In this connection, it is to inform you that the above said building has been inspected by the officer concerned of this department from fire safety point of view on 27.03.2022 in the presence of Sh. Shyam Mohan Gupta. During inspection, it has been observed that the said building is comprised of Ground + Mezz. Floor + 01 Upper Floors served with 02 staircases. The Fire safety arrangement such as fire extinguisher etc found provided. However, the following points have been noticed as shortcomings:-

1. Main pump 900 lpm & jockey pump 180 lpm found removed.
2. First aid hose reel found removed.
3. Underground water storage tank not checked as covered with flooring.

In view of the above shortcoming, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
(West Zone)

Copy to: -

1. The Executive Engineer (Building), South DMC, 9<sup>th</sup> Floor, Dr. S.P.M. Civic Centre, J.L.N. Marg, New Delhi-110002.