

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/ 2022/SZ/ 1110

Dated: 18/05/2022

To,

Sh. Vivek Shrivastava (JGM/E&M),
DMRC, Metro Bhawan, Fire Brigade Lane,
Barakhamba Road, New Delhi-110001.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Additional Staff Quarters Najafgarh Depot of line-3 of Delhi MRTS, New Delhi-110043.

Sir,

This has reference to your letter No. Nil dated 01/04/2022 on the subject cited above. In this regard, it is to inform you that the inspection of above said premises has been carried out by officers concerned of this department on 04/05/2022 to see the compliance of the requisite fire safety directives issued vide letter no. F6/DFS/MS/CGHS/BP/2006/63 dated 08.01.2007. Sh. Pushkar Singh (Sr. Fire Inspector) was present at the time of inspection.

During the course of inspection it was observed that the building comprised of seven blocks was issued FSC vide letter no F6/DFS/MS/2007/3071 dated 16.10.2007. Each block having ground plus six upper floors. The building is approachable to the fire fighting vehicles. The electrical wiring was seen concealed and the electric supply was passing through MCB's. The following shortcomings were observed:-

1. Hose reel system is provided but not functional in B, D & F blocks.
2. Down comer system provided but not functional.
3. Fire pump of 900 LPM capacity are provided but not functional.

You are advised to rectify the above-mentioned shortcomings for taking further action as necessary for grant of Fire Safety Certificate.

Yours Faithfully,


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE