

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/School/SZ/2022/235

Dated: 20/05/2022

To

The Principal,
SDMC Co-ED Pratibha Vidyalaya,
Nizamuddin West, New Delhi-13

Sub:- Regarding renewal of Fire Safety Certificate in r/o SDMC Co-ED Pratibha Vidyalaya, located at Nizamuddin West, New Delhi-13.


Sir,

With reference to email dated 08.04.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 05.05.2022 in the presence of Adra Imteyaz, (Principal) and it was observed that the building is comprised of ground + 03 upper floors. During the inspection following shortcomings were observed:-

1. Hose reels found non functional.
2. Fire pump found non functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

06/05/22
13/5

Copy to:-

The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.