

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2022/242

Dated: 23/05/2022

To,

The Principal,  
Aggarwal Model School,  
2586, Maharaja Agarsain Marg,  
Tri Nagar, New Delhi-110052.

**Sub: - Regarding Issuance of Fire Safety Certificate in r/o Aggarwal Model School Located at 2586, Maharaja Agarsain Marg, Tri Nagar, Delhi – 110035**

Sir,

Please refer to your Email dated 01/04/2022 on the subject cited above. In this connection, it is to inform you that the said building/premises were inspected by the officer concerned of this department on 10/05/2022 in presence of Mrs. Babita Gupta (Principal) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the said school is running at Stilt + Ground + 3 upper floors in a building comprised of Stilt + Ground + 03 Upper Floors. Fire safety arrangements Such as Fire Extinguishers, First –Aid Hose reels, Terrace pump, Over head water storage tank, etc. are provided. However the following Shortcomings were observed.

1. Width of staircase is provided 1 x 115cm & 1 x 90cm against requirement of 1.5 mtr each.
2. Width of corridor 90cm is provided against requirement of 1.5mtr.
3. Door size 90cm x 1 is provided against requirement of 1.20 mtr.
4. Terrace Pump of 450lpm is provided but not on auto mode.
5. Exit Sinages are found removed.

In view of above Shortcomings the application for Renewal of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier.

Yours faithfully

  
Atul Garg  
Director  
Delhi Fire Service

Copy to: -

1. The Director, Directorate of Education, old secretariat, Delhi.

e/c AP  
19/5/2022