

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/School/SZ/2022/262

Dated: 27/05/2022

To

The Principal,  
G.B. Pant Govt. Sarvodaya Bal Vidyalaya,  
Srinivaspuri New Delhi-110065.

**Sub:-** Regarding renewal of Fire Safety Certificate in r/o **G.B. Pant Govt. Sarvodaya Bal Vidyalaya located at Srinivaspuri New Delhi-110065.**


Sir,

With reference to your letter no. GBP/SBV/SNP/2022-23/672 dated 21.04.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 05.05.2022 in the presence of Dr. Akhtar (HOS) and it was observed that the building is comprised of two blocks (Ground + 02 upper floors & Ground + 01 upper floors). During the inspection following shortcomings were observed:-

1. First-aid-hose reels found non function.
2. Fire pump found non functional.
3. Terrace tank having total capacity of 10,000 liters shall be provided exclusively for fire fighting.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



**(Sunil Chawdhary)**

Dy. Chief Fire Officer  
Delhi Fire Service

9/c  
27/5

**Copy to:-**

The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.